

pozzo P4 Porta Nuova Garibaldi - Milano

CALCOLATO					
	1°gradino	2°gradino	3°gradino	4°gradino	risalita
Q (l/sec)	10,10	19,61	40,00	0,00	0,00
tempo (min)	livello piezometrico da riferimento (testa pozzo - p.c.)				
0	-11,44	-11,44	-11,44	X	-12,11
1	-11,69	-11,91	-13,24	X	-11,53
2	-11,70	-12,01	-13,56	X	-11,54
3	-11,71	-12,04	-13,68	X	-11,62
4	-11,71	-12,04	-13,75	X	-11,57
5	-11,71	-12,05	-13,80	X	-11,55
6	-11,71	-12,05	-13,85	X	-11,53
7	-11,71	-12,06	-13,94	X	-11,52
8	-11,71	-12,06	-13,95	X	-11,51
9	-11,71	-12,07	-14,00	X	-11,51
10	-11,72	-12,07	-14,05	X	-11,51
12	-11,72	-12,07	-14,10	X	-11,51
14	-11,72	-12,08	-14,14	X	-11,51
16	-11,72	-12,08	-14,14	X	-11,51
18	-11,72	-12,09	-14,18	X	0,00
20	-11,73	-12,09	X	X	0,00
25	-11,73	-12,09	X	X	0,00
30	-11,73	-12,10	X	X	0,00
35	-11,73	-12,10	X	X	0,00
40	-11,74	-12,10	X	X	0,00
50	-11,74	-12,11	X	X	0,00
60	-11,74	-12,11	-14,47	X	0,00

valore determinato analiticamente